




**NATIONAL PIPE & PLASTICS, INC.**

# QUAD-DUCT

## PVC Telecommunications Duct



National PVC QUAD-DUCT is manufactured from virgin PVC compounds with a cell class of 12454-B as determined by ASTM D-1784. Our QUAD-DUCT which is intended for use in fiber optic cable, coaxial cable, and small diameter cable installations is subjected to in-process quality control inspections to assure compliance with the appropriate manufacturing and performance standards listed below:

- ASTM Standard D-1784
- ASTM Standard D-1785

Nominal Size	O. D. Average	Minimum Wall	Overall Length	A Ref.
1-1/4	1.660	.140	20' 3"	5.25
1-1/2	1.900	.145	20' 3"	6.00
2	2.375	.154	20' 3"	7.00

Note \* This QUAD-DUCT is a system, pre-assembled at the factory which is typically made by clipping together a group of 4 COMM-DUCT-duct carriers (3 white and 1 grey). The overall length is 20' 3" and suitable for either direct burial or concrete encasement. A close tolerance integral bell and chamfered spigot end assure easy assembly. Once cemented this integral joint assembly provides a water and air tight duct system.